



State Policy Tracking: 2011-2012 Session

# Michigan

---

**HB 5273: Backup emergency generators**

Requires dialysis centers have backup emergency generators with sufficient capacity to provide electricity necessary to sustain dialysis treatments and to maintain enough fuel to maintain the operation of the generator for at least 48 hours. The backup emergency generator must be tested once a month for at least 30 minutes.

STATUS: In committee

**SB 390: Relating to certificate of need**

Establishes standards required for approval and delivery of services under a certificate of need for a vascular access center.

STATUS: In committee

---

For more information on these and other bills, visit your Legislature's homepage:

<http://www.legislature.mi.gov>